



कार्यालय, नगर पालिक निगम, भोपाल
विभाग - स्वास्थ्य विभाग

क्र.....२...../स्वा. विभाग/2026

भोपाल, दिनांक-19/05/2026

**SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

It is certified that an inspection team headed by Mr. Rajeev Saxena Health Officer, Nagar Nigam Bhopal. Inspected the **Delhi Public School BHOPAL, DPS Campus, Near Neelbad Crossing, Bhadbhada Road, Bhopal (M.P.)** on 19th May - 2026 and Found that the **Delhi Public School**, Have Safe Drinking Water Facilities for the Students and Members of Staff of the Institution and is Maintaining the Hygienic sanitation condition in the School Building & the Campus as per the norms prescribed by the Central/State/ U.T. Govt.

The above is Valid for a Period of Year – 2026 – 27

Signature with Seal
Name **RAJEEV SAXENA**
Designation **HEALTH OFFICER**

To,
Delhi Public School,
DPS Campus, Near Neelbad Crossing,
Bhabbhada Road, Bhopal (M.P.)



TC-16421

Format No. SRL/PHED/BPL/4.3

State Research Laboratory, (SRL)

Public Health Engineering Department. P.H.E.D.

Shyamla Hills, Bhopal, 462002, Email-labbpl@mp.nic.in, Phone-0755-4934796

ULR No.

TC	1	6	4	2	1	2	6	0	0	0	0	0	0	0	5	6	F
----	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

Test Report

Nature of sample :- Drinking Water Sample / Others		Not sampled by State Research Lab		Unique Identification No.	87
Sender's name and address To, DELHI PUBLIC SCHOOL GRAM GORA NEAR NEE'BAD CROSSING ROAD BHOPAL	Sender's letter no.	-		Sender's letter Date	12/05/26
	SRL Ref. No	112		SRL receipt date	12/05/26
	Date of analysis started	12/05/26		Date of analysis completed	13/05/26
	Quantity Of sample	Ok			

No.	Particulars of Samples
1.	BLOCK A WATER SAMPLE
2.	BLOCK B WATER SAMPLE
3.	BLOCK C WATER SAMPLE
4.	BLOCK D WATER SAMPLE
5.	PFC WATER SAMPLE

Sample details**RESULTS**

Field.. Testing		Discipline..Biological		Group..Water	Sub. Group..Drinking Water							
No	Characteristics	unit	Test Method	Specification Of Drinking Water As Per BIS:10500:2012 RA Sep 2022	Results in samples							
					1	2	3	4	5	6	7	8
1	Ecoli	per 100 ml,	APHA 24 rd edition, 9223 B	Should be Absent for treated water and water in distribution system	NIL	NIL	NIL	NIL	NIL			
2	Total coliform	per 100 ml	APHA 24 th edition 9223 B	Should be Absent for treated water and water in distribution system	-	-	-	-	-	-	-	-

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. The results refer only to tested samples and parameters tested.
3. Water sample per 100 ml.

Reviewed By

(Soni Sharma)

Technical manager

STATE RESEARCH LABORATORY
P. H. E. DEPARTMENT BHOPAL

Issue No. 121 /S.R.L./PHED/BPL /2026 Issue Date 13/05/26

End of Report